



NOTIFIED BODY No. 1293

EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0344

of September 12, 2012

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Conventional manual call point (re-armable) P440

is a manual call point type A, designed to work with conventional fire panels, the manual call point P440 is used to manually initiate an alarm condition on conventional fire prevention systems. The P440 is a resettable manual call point, the alarm condition will be initiated by pressing on the operating face of the manual call point. The red LED indication indicates, when turned-on, the alarm condition

placed on the market by

URMET S.p.A.

Via Bologna 188/C, 10154 Torino, Italy

and produced in the factory

VAT No. IT05288880965

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPÚ a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

EN 54-11: 2001/A1: 2005

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on September 12, 2012 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Marek H u d á k



Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

044489